

Certificate

No. z4406d-16-E

Customer:

Telegärtner Karl Gärtner GmbH
Lerchenstr. 35
71144 Steinenbronn, Deutschland

Class I

Test sample(s):

Data Cable:

Dätwyler CU 8203 4P AWG 23 S/FTP Cat.8.2 IEC FRNC/LSOH

Part no.: 192009

Patchcord:

Dätwyler CU 8206 4P Flex AWG 26 S/FTP Cat.8.2 IEC FRNC/LSOH

Part no.: 192068

Connector:

Telegärtner AMJ Cat 8.1 T568A/B

Part no.: J00029A8000

Applied standard(s):

ISO/IEC TR 11801-9901 Ed. 1.0: 2014

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

2 Connector Channel (30m), Copper, Class I

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report **no. P4406d-16-E** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of issue.

Bexbach, 16. December 2016



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



*Test laboratory accredited by DAkkS in accordance with DIN EN ISO/IEC 17025.
The accreditation is valid for the test methods listed in certificate D-PL-17559-01-00.*

GHMT AG

In der Kolling 13
66450 Bexbach / Germany

P.O. box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**